



EFFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş.
TOSB TAYSAD Organize San. Böl. 1. CD. 15. Yol No: 1
Şekerpınar - Çayırova
Kocaeli-TÜRKİYE
www.efectis.com

TEST CERTIFICATE

Certificate Nr: EEA – 1600 – 0010

The related resistance to fire test was carried out at **Efectis Era Avrasya Test Laboratories** on 26.04.2016 in accordance with EN 1364-1:2015 standard for the product as described below:

Polyisocyanurate (PIR) Filled Sandwich Panel Partition Wall System **“ASSAN FR”**

FIRE RESISTANCE CLASSIFICATION

E 60, EI 30

Placed on the market by

KIBAR INDUSTRY CO. & ASSAN PANEL SAN. Ve TİC. A.Ş.
Yayla Mah. D - 100 Karayolu Rüya Sk. No:2 Assan Tesisleri, Tuzla, İSTANBUL/TURKEY

And Produced In the Factory

KIBAR INDUSTRY CO. & ASSAN PANEL SAN. Ve TİC. A.Ş.
Thagret Eljoub - Al Mafraq - Jordan /P.O.Box 460742 Code: 11946

This test certificate is a declaration of the test results and does not represent any type approval or certification of the product. All details related to product specifications and field of application are described in the report Nr. **EEA – 16– 054**.

Ali BAYRAKTAR
Laboratory Manager

