

To whom it may concern,

We hereby as EFECTIS ERA AVRASYA Laboratories confirm that;

The resistance to fire test was carried out at Efectis Era Avrasya Test Laboratories in accordance with EN 1363-1 and EN 1364-1 standards for the product which was manufactured by **ASSAN PANEL SAN. VE TİC. A.Ş.** as described below.

Product:

ASSAN PANEL – PIR Filled Sandwich Panel System

Resistance to fire classification**E45**

The preparation process of reports is in progress.

Best regards,

01.07.2014

Kocaeli



Onur DAĞ
Operasyon Müdürü

